

Part 1- General**1.1 SCOPE**

To furnish all labor, materials and equipment necessary or required to fully complete the installation of the elevator as shown on the drawings and specifications. This suggested specification is intended to cover the complete installation of the Concord ORION Commercial LU/LA Elevator design.

1.2 SYSTEM DESCRIPTION

The elevator assembly shall consist of a power unit, car, rail guide system, 1:2 cable hydraulic lifting device, hoistway doors, car doors, control system, signals and alarms, electrical wiring, and parts and accessories necessary to provide required performance, operation, code and safety requirements.

1.3 QUALITY ASSURANCE**1.3.1**

The elevator shall meet or exceed the applicable regulations of all governing agencies and be in compliance with the applicable sections of the most current edition of the following codes and standards:

- a) ASME A17.1 "Safety Code for Elevators and Escalators, Limited Use/Limited Application Elevators".
- b) CSA B44-00 "Safety Code for Elevators, Section 5.2 Limited Use/Limited Application Elevators"

Note: ASME A17.1 & CSA B44 contain harmonized requirements.

- c) ICC/ANSI A117.1-1998 "Accessible and Usable Buildings and Facilities".
- d) ANSI/NFPA 70-1999 "The National Electric Code" (NEC).
- e) ADAAG "Americans With Disabilities Act Accessibility Guidelines" (where applicable).
- f) CSA B44.1/ASME A17.5 "Elevator and Escalator Electrical Equipment".
- g) Local codes and regulations, as applicable.

1.3.2

Requirements of the Regulatory Agencies:

- a) Fabricate and install Work in compliance with all applicable jurisdictional authorities.
- b) File shop drawings and submissions to local authorities as the information is made available. Company pre-inspection and jurisdictional authority inspections and permits are to be made on a timely basis as required. Work will include all inspections and re-inspections that are required to ensure licenses are issued.

1.3.3

Subcontractor Qualifications:

- a) Execute work of this specification only by a contractor/company who has adequate product and public liability insurance in excess of one million dollars.
- b) Skilled tradesmen must be employees of the contractor to perform the work on a timely basis. Employees must be trained by the manufacturer and be supervised by the elevator contractor.

1.3.4

Substitutions:

No substitutions will be considered unless written request for approval has been submitted by the bidder and received by the architect at least 10 days before the date of receipt of bids. Each such request shall include a complete description of the proposed substitute including drawings, test data, photographs, and any other information needed for consideration.

Part 2 - Preparatory Work by Others

2.1

The following preparatory work to accommodate/receive the elevator is to be done by others:

2.1.1

Power unit machine room to meet applicable codes and standards.

2.1.2

Permanent power to operate the elevator to be provided to a lockable fused/cartridge type disconnect switch with auxiliary contact/switch for emergency battery lowering. Provide 110-volt lighting supply and disconnect. Refer to architectural drawings for permanent power specifications and location of the disconnects.

2.1.3

Provide appropriate sleeves for both the electrical conduit and hydraulic line from the power unit enclosure to the hoistway (as shown on drawings). Trenching may be required if the machine room is not adjacent to hoistway.

2.1.4

Provide machine room light and light switch, located to comply with applicable codes and standards.

2.1.5

Provide an enclosed, plumb and square hoistway with smooth interior surfaces. Include for fascias or furring of hoistway interior where applicable.

2.1.6

Suitable lintels over landing entrances are to be provided and provide rough openings as per elevator contractors' shop drawings.

2.1.7

Provide substantially level pit floor slab to support loads indicated on the elevator contractors' shop drawings.

2.1.8

Provide adequate support for guide rail fastenings.

2.1.9

Provide light, receptacle and switch in the pit, located to comply with applicable code.

2.1.10

Provide pit water proofing or sump pump, if required, as allowed by code.

2.1.11

Provide pit ladder for pits 3'-0" (914 mm) or more in depth.

2.1.12

Provide finish grouting and masonry around doorframes.

2.1.13

Provide finish painting of landing entrances.

Part 3- Submittals

3.1 Shop Drawings

The shop drawings shall show a complete layout of the elevator equipment detailing dimensions, clearances and location of machinery. Including, but not limited to, the following:

3.1.1

Drawings showing the dimensions including plans, elevations, and sections to show equipment locations.

3.1.2

Load and reaction drawings shall be provided by the elevator manufacturer and detailed on drawings.

3.2

SAMPLES

Part 4- Product Data**4.1 MANUFACTURER/ PRODUCT**

Elevator shall be the CONCORD ORION Commercial LU/LA Elevator manufactured by Concord Elevator Inc. Toll Free Number (800) 661-5112 and (905) 791-5555, Fax (905) 791-2222

Installed by Dealer:	Name _____ Number _____
Rated Load:	1,400 lbs. (635 kg.)
Rated Speed:	30 fpm (0.15 m/s)
Car Dimensions:	48" W x 54" L Depth (1220 mm x 1372 mm)
Operation:	Single Automatic Push Button
Power Supply:	220-Volt, Single Phase, 60 Amp or 208-Volt, 3 Phase, 30Amp.
Travel Distance:	25 feet (7.6 m) maximum as per ASME A17.1 Part 25 NOTE: Elevator can travel up to 30 feet (9.1 m)
Levels Served:	Maximum 4
Number of Openings:	Maximum 2
Lighting Supply:	110-Volt, Single Phase, 60 cycle, 15 amps
Door Opening:	36" x 6' 8" (890 x 2030 mm) Nominal
Jack Type:	1:2 cable hydraulic
Pump Type:	Submersible with Variable Speed Valve
Hoistway Door/Cab Door:	2-Speed Horizontal Sliding Hoistway Door with 2-Speed Horizontal Sliding Cab Door
Car Controller Type:	Magnetic Sensor
Leveling Device Type:	Magnetic Sensor

4.2 SIGNAGE**4.2.1**

The elevator shall have all necessary signs, capacity plates, and data signs as per the local and national Codes and Standards.

4.2.2

A capacity plate indicating the rated load in pounds and kilograms and operating instructions shall be furnished by the manufacturer and fastened in a prominent place at each landing and in the cab. The capacity plate and operating instructions will be engraved on non-glare, micro-surface, white letters on a blue background, self-adhesive, flexible plastic material. The letters and figures stating the capacity shall not be less than 1/4" in height.

4.3 FULLY AUTOMATIC OPERATION

The operation shall be single automatic push button. Each landing shall be equipped with a single light up button/digital floor indicator and audible arrival chime. Upon momentary pressure of the landing or car button, the call shall register in the control system and remain in memory until answered.

4.4 CAR ENCLOSURE**4.4.1 WALLS**

Steel cab with 3/4" (19 mm) clip-on fire rated laminated panels. Painted cab frame reveal to be Concord standard black or architectural white. Clip-on Panel selected from Concord's Standard plastic laminate selection.

4.4.2 CEILINGS

Non-removable Hi Gloss Architectural white painted baked enamel steel ceiling with 4 incandescent down lights

4.4.3 FLOOR

Steel frame and flooring with plywood sheeting.

4.4.4 HANDRAIL

One (1) stainless steel handrail shall be located on control wall of the cab.

4.4.5 EMERGENCY OPERATION

The car will be equipped with a battery powered emergency lowering and door opening device and alarm which is automatically actuated in the event of failure of the normal building power supply. Battery will be rechargeable with an automatic recharging system.

4.4.6 EMERGENCY LIGHTING

In the event of a main power supply failure, an integral, battery powered emergency light will provide cab lighting.

4.4.7 Tactile Plates

Provide metal tactile plates 1 1/4" X 1 1/4" on the cab control panel beside the appropriate button indicating the floor number and/or function. Also provide metal tactile plates 3" X 4" at each floor located on the doorjamb indicating the appropriate floor number.

4.4.8 CAR OPERATING PANEL

Car operating panel shall be hinged and shall consist of metal push button with halo lighting for each landing, emergency alarm, keyed stop switch, door open and close buttons all mounted on (#4 finished). Stainless steel panel. The car-operating panel will be engraved with Fireman Service instructions.

4.4.9 Car Travel Lanterns

Provide a visual indicator to indicate the direction of travel of the car and audio signal upon floor arrival.

4.4.10 DIGITAL FLOOR INDICATOR

A digital floor indicator located in the control panel will display the location (floor number) of the elevator in the shaft as well as the direction of travel.

4.4.11 CAR LIGHTING

The car lighting shall consist of four- (4) low voltage incandescent down lights. The failure of one lamp shall not cause the remaining lamps to extinguish.

4.4.12 AUTOMATIC LIGHTS

Overhead lights in the car compartment shall turn ON automatically when the elevator door is opened and stay ON while the elevator is in use. The elevator lights will shut OFF by a timer when the elevator is not in use.

4.5 PLATFORM TOE GUARD

A platform toe guard shall be provided at each car entrance opening to extend below car entrance opening for safety.

4.6 LEVELING DEVICE**4.6.1**

The elevator shall be provided with a 2 way-leveling device, which will maintain the car within 1/2" (13 mm) of the landing, by magnetic sensor.

4.6.2

Leveling device switches shall be located in a position to be inaccessible to unauthorized persons.

4.6.3

Hoistway car position signals shall be magnetically sensed for quiet operation.

4.7 TWO SPEED HORIZONTAL SLIDING HOISTWAY DOOR/CAB GATE**4.7.1 Cab Door Operation**

- a) Power operated, two speed horizontal sliding, zinc wipe coated, steel panels providing a clear opening of 36" x 80" (914 mm x 2032mm) shall be provided.
- b) Doors on the car and at the hoistway entrances shall be power operated by means of a solid-state 24 volt D.C. operator with smooth quiet belt drive transmission, operable during power failure.
- c) Door operation shall be automatic at each landing with door opening being initiated as the car arrives at the landing and closing taking place after expiration of an adjustable time interval.
- d) All control adjustments shall be potentiometer regulated.
- e) The door shall be equipped with an infrared self-contained light curtain that will stop and reverse the doors should it detect an obstacle.
- f) The car doors shall be equipped with a master door clutch to control the individual landing door electrical-mechanical interlocks.
- g) The car door electric contact shall prevent the elevator from moving away from the landing unless the car door is in the closed position and the controller will monitor the door contacts and register a fault if any have been bypassed
- h) The car doorsill shall be extruded aluminum.

4.7.2 Hoistway Doors

- a) Two speed horizontal sliding, zinc wipe coated, steel panels providing a clear opening of 36" (914 mm) x 80" (2032 mm) shall be provided at each landing.
- b) Frames shall be of bolted construction for a one-piece unit assembly comprised of head and side jamb sections.
- c) The door assembly shall be 1 1/2 UL/ULC labeled and provided with approved electrical mechanical interlocks.
- d) The landing doorsill shall be extruded aluminum with non-slip wearing surfaces and grooves for door guides.

4.8 HYDRAULIC POWER UNIT

- a) The pump and motor shall be the submersible type installed inside the oil tank.
- b) The controller shall be integrally mounted on the power unit frame.
- c) Control circuitry to be Programmable Logic Controls and be located on the pump unit.
- d) The power unit control valve shall be a variable speed proportional valve type that includes all hydraulic control valving inherently.

This valve shall incorporate the following features:

- (i) Up and down acceleration and deceleration speed adjustment for a smooth starts and stops.
- (ii) Smooth stops at each landing shall be an inherent feature of the valve.
- (iii) Adjustable pressure relief valve.
- (iv) Manually operating DOWN valve to lower elevator in an emergency.
- (v) Pressure gauge indicating in P.S.I. and Bars.
- (vi) Gate valve to isolate cylinder from pump unit.
- (vii) Negative pressure switch

4.9 NEGATIVE PRESSURE SWITCH

In addition to the standard operating features of the hydraulic control valve, there shall be a pressure sensitive check valve that will activate when negative pressure is sensed in the hydraulic system. The check valve will close and stop the hydraulic jack from descending immediately on sensing negative pressure.

4.10 CYLINDER AND PLUNGER

4.10.1

The cylinder shall be constructed of steel pipe of a sufficient thickness and suitable safety margin. The top of the cylinder shall be equipped with a cylinder head with an internal guide ring and self-adjusting packing.

4.10.2

The plunger shall be constructed of a steel shaft of a proper diameter machined true and smooth. The plunger shall be provided with a stop electrically welded to the bottom to prevent the plunger from leaving the cylinder.

4.11 CABLE

Minimum of two 3/8" (10 mm).

4.12 SAFETY DEVICE

A "slack/broken cable" safety device shall be supplied, which will stop and sustain the elevator and its rated load, if either of the hoisting cables becomes slack or breaks. The safety device shall be resettable by the operation of the elevator in the upward direction. A switch shall be mounted in such a position to sense the operation of the safety device, and will open the safety circuit to the controller to prevent operation of the elevator in either direction.

4.13 GUIDE YOKE

The 1:2 guide yoke/sheave arrangement shall be supplied with a sheave, guide shoes, roller bearings and adjustable cable guards. The sheave shall be finished with rounded grooves to fit the cables.

4.14 NORMAL TERMINAL STOPPING DEVICES

Normal terminal stopping devices shall be magnetically sensed at the top and bottom of runway to stop the car automatically.

4.15 GUIDE RAILS AND BRACKETS**4.15.1**

Steel 8lb/ft“T” guide rails and brackets shall be securely fastened to the building structure.

4.15.2

Brackets shall securely hold the guides in a plumb and true position regardless of car loading.

4.15.3

Guides shall be bolted through the hoistway enclosure with “back-up” plates, washers and nuts. Subject to architects’ alterations and approvals.

4.16 CAR SLING**4.16.1**

Car sling shall be fabricated from steel members with adequate bracing to support the platform and cab.

4.16.2

The buffer-striking member on the underside of the car must stop the elevator before the plunger reaches its down limit of travel.

4.16.3

Guide shoes to be solid slipper type with polyurethane inserts.

4.17 OVERSPEED GOVERNOR

Elevator to be equipped with an overspeed governor complete with tension weight and brackets; high strength wire rope and attachment fittings, all in conformance with the applicable code sections. The governor shall be traction driven, self-resetting, field adjustable and be provided with a means to seal the tripping speed.

4.18 CAR TOP INSPECTION STATION

Provide a car top inspection station consisting of a stop button and constant pressure Up and DOWN button. The car top control will override all other controls. Also provide a 110-volt GFI outlet socket and light.

4.19 WIRING

All wiring and electrical connections shall comply with applicable Codes, insulated wiring shall have flame retardant and moisture proof outer covering and shall be run in a conduit or electrical wireways. Traveling cables shall be flexible and suitably suspended to relieve strain.

4.20 FINISH

Electrostatically applied baked polyester gloss powder coating paint finish.

Part 5- Execution**5.1 EXAMINATION**

All site dimensions shall be taken to ensure that tolerances and clearances have been maintained and meet local regulations.

5.2 PREPARATION

Pre-inspect the construction and service requirements for “Work by Others.” These requirements will be included in drawings, diagrams, engineering data sheets and special instructions before the work commences.

Part 6- Warranty**6.0 WARRANTY**

Concord Elevator shall provide a Manufacturer’s limited parts warranty as outlined in Appendix A.

Part 7 - Owner’s Instruction & Manual**7.0 OWNER’S INSTRUCTION & MANUAL**

After installation is completed, the contractor shall instruct the owner in the proper use, operation and maintenance requirements of the elevator. Instructions to also include emergency procedures and safety rules and precautions. The contractor shall also supply the owner with an Owner’s Manual detailing the operating, safety, and maintenance procedures of the elevator.

Appendix A

Concord Elevator Manufacturer's Limited Product Warranty

Term of warranty – this warranty is valid for a period of 36 months from the date that the product shipped from our factory. Purchase price for product must be paid in full for manufacturer to release parts under this warranty.

Coverage – this warranty applies to the repair or replacement, at Manufacturer's option, of parts that fail due to defective material or workmanship. Manufacturer may, at its option, provide factory reconditioned parts. This warranty is provided to the Authorized Concord Dealer on behalf of the final purchaser of the product and is not transferable. The Manufacturer's warranty does not cover labor charges for the removal, repair or replacement of warranty parts but such costs may be covered for a period of time by Authorized Dealer's warranty, which is provided to purchaser separately.

Conditions:

- 1) This warranty only applies to products installed and maintained by a Concord Elevator Authorized Dealer in conformance with all applicable local and national codes.
- 2) The warranty is void if regular inspection and maintenance of product is not being carried out by an Authorized Concord Dealer in accordance with the recommendations contained in the Owner's Manual. It is the Owner's responsibility to keep records of all such service.
- 3) This warranty does not apply to the following:
 - 1) Consumable items which include: light bulbs, batteries, oil seals, mechanical switches, guide shoe inserts, drive belts, hydraulic fluids, greases, oils etc.
 - 2) Structural or cosmetic components that are subject to normal wear and tear, external forces and/or misuse. This includes metal panels, glass, plexiglass, gates, doors, buttons, switches, upholstery, trim etc
 - 3) Items that require periodic assessment, maintenance and/or replacement. This includes paint, caulking, weather seals, etc
 - 4) Malfunction or damage to product caused by accident, misuse, abuse or vandalism, lack of proper maintenance, improper installation or placement of product, neglect, improper adjustment, modification or alteration, structural condition of building or hoistway, overloading, failure to follow operating instructions or acts of God.

Standard Procedures:

Required warranty parts will be shipped at Concord Elevator's expense by UPS ground. Expedited or air shipment of parts is available at Dealer's request and expense. Some parts covered under this warranty may be commercially available from a source close to the job site and Concord will reimburse Dealer for cost to purchase these items provided that approval is obtained from Concord's Technical Support Department in advance.

Disclaimers:

Concord disclaims liability for any personal injury or property damage resulting from the operation of a product that has been modified from the original Concord design. No person or company is authorized to change the design of this product without written authorization by Concord.

Concord's obligation under this warranty is exclusively limited to the repair or exchange of parts that fail within the applicable warranty period.

Concord assumes no responsibility for expenses or damages, including incidental or consequential damages. Some states and/or provinces do not allow the exclusion or limitation of incidental or consequential damages so the above limitation may not apply to you.